

## Addendum 002

November 21, 2025

### Williams Fire Station Phase 2

Ella Street at Husted Road, Williams, California 95987

#### TO ALL RECORD PLANHOLDERS :

Notice is hereby given that the following clarifications, corrections, additions, and deletions as hereinafter set forth shall apply to the Contract Document Drawings, dated 10/25/25, the Contract Document Specifications, and the Public Works Bid and Contract Documents, for the subject project, as described herein, and shall be made a part thereof, and subject to all requirements thereof, as if originally drawn or specified.

Receipt of this Addendum No. 2 must be acknowledged on the form of Proposal in writing. Addendum No. 2 includes NO CHANGE in the Bid Date.

#### Item 2.1 Reference ALL BID DOCUMENTS

a) ADD the following statement to ALL Bid Documents:

#### 15. BUILD AMERICA, BUY AMERICA ACT (BABAA)

The recipient must comply with the provisions of the Build America, Buy America Act (the "Act"). Pub. L. No. 117-58, §§ 70901-52, enacted on November 15, 2021. The Act requires that "none of the funds made available for a Federal financial assistance program for infrastructure may be obligated for a project unless all of the iron, steel, manufactured products, and construction materials used in the project are produced in the United States." Recipients of an award of Federal financial assistance from a program for infrastructure are hereby notified that none of the funds provided under this award may be used for a project for infrastructure unless:

- c. All iron and steel used in the project are produced in the United States. This means all manufacturing processes, from the initial melting stage through the application of coatings, occurred in the United States;
- d. All manufactured products used in the project are produced in the United States. This means the manufactured product was manufactured in the United States, and the cost of the components of the manufactured product that are mined, produced, or manufactured in the United States is greater than 55 percent of the total cost of all components of the manufactured product, unless another standard for determining the minimum amount of domestic content of the manufactured product has been established under applicable law or regulation; and
- e. All construction materials are manufactured in the United States. This means that all manufacturing processes for the construction material occurred in the United States.

The BABAA requirement applies to the entirety of an infrastructure project, even if only a portion of the project is funded by Federal funds. The requirement applies to each product, manufactured good, or construction material incorporated in the project.

See Exhibit A (attached herein) for BABAA Requirements

**Item 2.2 Reference PUBLIC WORKS BID AND CONTRACT DOCUMENTS :  
1.1 INVITATION TO BID**

a) REVISE the following statement:

The successful bidder must possess the following classification or type of contractor's license issued by the Contractors State License Board: Class A, ~~C-12~~ or ~~C-8~~, **B**, California.

b) COPY of the Pre-Bid Mandatory Sign-In sheet is herein attached.

c) COPY of the Planholders List through 11/21/25 is herein attached.

**Item 2.3 Reference PUBLIC WORKS BID AND CONTRACT DOCUMENTS :  
4.20 TIME OF COMPLETION**

a) REVISE the following statement:

The time allowed for the completion of the work ~~is stated in the Contract~~ **shall be 365 Calendar Days (1 year).**

**Item 2.4 Reference SPECIFICATION SECTION 07410 METAL ROOFING,  
SIDING, AND SOFFIT**

a) REVISE the following statement:

2.02.K Soffit Vent Screenshot: Fry WPM-75-V-300 aluminum 3" vented soffit molding. **Vent Screenshot shall be continuous on north and south sides of the Out Building.**

**Item 2.5 Reference SPECIFICATION SECTION 08710 FINISH HARDWARE  
3.03.C HARDWARE GROUPS**

a) REVISE the following Hardware Groups:

GROUP 4 -

**Not Used**

- ~~1 Flat Track Hanger Track Kit 0105.200, sized to opening~~
- ~~2 Bow Handle 0191.00001, each door~~
- ~~1 Door Latch 1025.00019~~
- ~~1 Heavy Hasp 0182.00020ZC~~

GROUP 5 -

- 3 Hinges CB1900 - 4 1/2" x 4 1/2" x 652
- 1 Lockset D70PD x Rho x 626
- 1 Closer 4110N x 689** **Doors 118D,118E,143A,158A only**